

Town of Beacon Falls

GENERAL PERMIT FOR THE DISCHARGE OF STORMWATER FROM SMALL MUNICIPAL SEPARATE STORM SEWER SYSTEMS (MS4)

2014 Annual Report Permit No. GSM000065

January 07, 2015
NYE PROJECT # 2009-004



NAFIS & YOUNG

Civil/Environmental Engineering & Surveying

1355 Middletown Avenue
Northford, CT 06472
Phone No.: (203) 484-2793
Fax No.: (203) 484-7343

Introduction

The Town of Beacon Falls submits the following Annual Report updating the status and compliance with the Town's Stormwater Management Plan. This report meets the State of Connecticut Department of Energy & Environmental Protection (CTDEEP) requirements as outlined in the General Permit for the Discharge of Stormwater from Small Municipal Separate Storm Sewer Systems (MS4), section (i) Reporting and Record Keeping Requirements.

Any individuals that wish to comment on this annual report or the Town of Beacon Falls's Stormwater Management Plan may contact Mr. Lawrence Secor at Nafis & Young Engineers, Inc at (203) 484-2148 or by email at larry.secor@nafisandyoung.com.

TABLE OF CONTENTS

Introduction.....	i
1.0 History	1
2.0 Compliance	2
Section 1: Public Education and Outreach	2
Section 2: Public Involvement / Participation	4
Section 3: Illicit Discharge Detection and Elimination	5
Section 4: Construction Site Stormwater Runoff Control	6
Section 5: Post Construction Site Runoff Control	8
Section 6: Pollution Prevention / Good Housekeeping	9
3.0 Monitoring Data.....	10
4.0 Summary of Planned Stormwater Activities During the Next Reporting Cycle	10
5.0 Changes In Any Identified Measurable Goals or Implementation Dates	10

APPENDICES

Appendix I: STORMWATER MONITORING REPORTS

Appendix II: STORMWATER BMPS, OUTREACH EXAMPLES and REPORTS

1.0 History

The Town of Beacon Falls began working on a stormwater plan during the winter of 2002/2003 to meet a projected implementation date of April 2003. The Town worked with Nafis & Young Engineers, Inc. (NYE) in developing and writing this plan. The Town completed a draft plan after receiving a final copy of the CTDEEP general permit requirements on January 9, 2004. The "State of Connecticut Department of Transportation Draft Stormwater Management Plan" was used as an outline for the Town's plan.

In 2004 the written plan was then given to the appropriate personnel within the Town of Beacon Falls's Conservation Commission, Inland Wetlands Agency, Planning & Zoning Commission and Public Works, the town posted a legal notice in both the Town Hall and the Public Library to inform the public that a copy of the plan was available in the Town Library for review by residents. The town did not receive any comments from the public.

In early 2005 the final draft of the plan was completed and is now available at the both the Town Hall and Public Library. In 2005 the Council of Governments of the Central Naugatuck Valley (COGNAV) arranged with TeleMedia Cable to air an EPA video on local public access television entitled "*After the Rain*" on two nights in December. A brochure created in conjunction with the Beacon Falls Conservation Commission/Inland Wetlands Agency that details the importance of storm water quality and the impact on the environment was distributed at the Town Hall and the Town Library. The Town also posted a poster in the Public Works garage and Town Hall to promote public awareness best management practices of storm water management during construction.

NYE has conducted ten (10) annual stormwater sampling events starting in the summer of 2004. Samples of six representative outfalls, two industrial, two commercial and two residential were taken on July 13, 2004, June 28, 2005, July 28, 2006, April 12, 2007, May 08, 2008, November 13, 2009, November 04, 2010, September 20, 2011, September 28, 2012, December 23, 2013 and April 30, 2014.

The Town purchased a handheld GPS/PDA system for mapping its stormwater outfalls and the required software to manage the collected data. The GPS/PDA and software was turned over to the Town's Public Works Department for continued mapping of the Town's outfalls. The final maps will be posted in the Public Works Department when it has been completed.

The Town Public Works Department and the Town Conservation Commission has initiated the storm drain-marking program with the initial labels being provided by the CTDEEP Office of Long Island Sound Programs. The Town completed marking its catch basin system in 2010. Additional catch basins were marked in 2012-2014 as required.

As of this report the town has not received any comments from the CTDEEP concerning the Town's Draft Stormwater Management Plan. This annual report is based upon that

draft plan, which was updated in January 2009 for the current five-year permit cycle. The Town has kept most of the Best Management Practices (BMPs) already in use. No additional testing was performed in 2012 to address the Total Maximum Daily Load for indicator bacteria in the Naugatuck River. The Town is still charged with reducing indicator bacteria by an average of 61% to meet current water quality standards for the Naugatuck River.

The Town is actively involved in the CTDEEP Aquifer Protection Area (APA) program. In 2010 the Town adopted its APA regulations. The APA is located on the southwest corner of the Town and no commercial development exists.

In 2011, the Town re-registered the Public Works Garage and Transfer Station for the revised CTDEEP General Permit for the Discharge of Stormwater Associated with Industrial Activity. The Town performed the required stormwater outfall sampling in the October-December 2011 quarter. During 2012 some changes to the PW grounds resulted in the loss of the stormwater outfall conveyance (swale). The CTDEEP was notified in writing and outfall sampling was suspended until a conveyance is installed or naturally formed at the site.

The Town of Beacon Falls participated in the “Household Hazardous Waste Collection Central Naugatuck Valley Planning Region” three collections April, July and October 2014. Sixty-Two (62) Beacon Fall's households participated in these collections that dispose of 525 gallons of household hazardous wastes. This was an increase over 2013's amounts.

Any changes made to the Town's updated plan as a result of requests or comments by the CTDEEP will be reflected in subsequent annual reports.

2.0 Compliance

Many of the Town's goals for the first year of the second permit were to continue building a foundation for further implementation of the Stormwater Management Plan. The Town adopted both the “Illicit Discharge and Connection Stormwater Regulation” and “Post Construction Stormwater Ordinance”. Through the process of adopting these ordinances the many procedures already being followed by the Town such as Planning and Zoning and Inland Wetland enforcement inspections will improve. Construction plan reviews have included reviewing stormwater management and erosion controls and the Town will continue these procedures but with the new ordinances in place the effectiveness of this process is improving. A large share of the effort was directed towards the education of Town officials and employees with regards to their role within the General Permit. The Best Management Practices (BMPs) chosen by the Town are addressed below:

Section 1: Public Education and Outreach

1. Brochures / Fact Sheets

Goal: Display and Distribute Brochures

The finished brochure was distributed at a Conservation Commission and Inland Wetlands Commission meeting in early 2005. It was approved for publication and was distributed at the Town Hall and the Library.

In 2006 the Beacon Falls Conservation Commission distributed 2000 pamphlets to each family through the Town's local school system. An additional 500 pamphlets were given to the Town's Building Inspector to be given out with every permit application package. The Beacon Falls Town Clerks office still distributes pamphlets as required.

2. Alternative Information Sources

Goal: Develop web site, display poster for Town, and Public Service Announcement (PSA) for local television.

The Town's web site is now up and running. This will greatly improve the information being available to the public.

The poster has been displayed at the Town Hall and the Public Works Garage. In December of 2005, the local cable company aired an EPA video entitled *After the Rain* on two nights.

The Town Conservation Commission has an active website and they publish information concerning stormwater pollution control on this website for the town. This Commission hosted a Community Forum on October 16, 2008 that included stormwater Phase II information and outreach.

In 2011 two USEPA brochures were included in the report's appendices "Make your home The Solution to Stormwater Pollution!, A Homeowners Guide to Healthy Habits for Clean Water" and "After the Storm, A Citizen's Guide to Understanding Stormwater". These were posted on the Town's website as included in the 2011 Annual report.

3. Library of Educational Materials

Goal: Make information available to town employees and the community

A library of educational materials is being developed and maintained at the CTDOT headquarters. As these materials are made available to the various towns in the state, materials will be procured for the various town departments as a reference for stormwater management issues.

Information on Internet websites (USEPA, CTDEEP) has also been used for reference and ideas.

4. Storm Drain / Marking Stenciling

Goal: The Town applied to CTDEEP for the drain-marking kit and received some labels for this purpose. In summer 2006 the town of Beacon Falls's public works department was given the assignment of storm drain marking. The Town is looking for resources/volunteers to continue with the program. Brochures will be distributed to the local street residences as the labeling occurs on their respective streets.

In 2008 the Conservation Commission took over this program and will start labeling in spring 2009. Outreach and a "How to Demonstration" were presented to High School students and covered by the local Press. In 2010 the Town's completed marking most of its catch basins. In 2012 the Town continued to mark catch basins as new roads (Blackberry Hill) were completed. This work was continued in 2014 as required and is planned for 2015.

5. Watercourse Signage

Goal: Determine what watercourses and how best to expand CTDOT tributary signage program

The CTDOT already maintains signage for certain watercourses within the Town. Officials from the Town are currently looking for areas within the Town to expand this program.

Section 2: Public Involvement / Participation

1. Presentation of Draft SWMP

Goal: SWMP

The final SWMP was completed in February 2005 and was made available to certain officials within the Town. It was also made available for review by the public after the posting of a public notice in the local newspaper.

This plan was updated in early 2009. The Town assigned Commissions (Inland Wetlands and Conservation) as well as the Public Works Department have taken ownership of their respective parts of the Plans and are implementing them as required.

2. Public Information Meetings

Goal: Brochures distributed

A brochure has been created and distributed by the Conservation Commission and is available at the Town Hall and Public Library.

3. Storm Drain / Marking Stenciling

Goal: The Town lined up volunteers to implement this program in Spring 2009. It was expected to be completed at the end of this permit cycle.

4. Lake and Watershed Associations / Authorities

Goal: Identify all local watershed Associations / Authorities and meet with representatives of all local groups

One of the leading association is the Housatonic Valley Association which is actively working programs that effect both the Housatonic and Naugatuck Rivers benefiting the Town of Beacon Falls in the areas were these rivers flow through or along the Town borders.

Other water associations and authorities are being contacted to see how their resources could best benefit the Town on these issues.

Section 3: Illicit Discharge Detection and Elimination

1. Town Policy Regarding Non-Stormwater Discharges

Goal: Policy Implemented, begin process of improved inspections and enforce compliance.

The town's Board of Selectmen passed an Illicit Discharge and Connection Stormwater Ordinance in early 2006 and assigned responsibility for enforcement to the Town's Inland Wetlands and Watercourses Commission.

An "Illicit Discharge Detection and Elimination Manual" was created for reference and training of town personnel involved in this BMP.

2. Storm Sewer Map(s)

Goal: Mapping outfalls

The Town, using its Global Positioning System (GPS), PDA and associated software mapped all outfalls 15" or greater in the "urbanized" areas of the Town in 2005.

In 2006 outfalls 15" or greater the mapping has expanded and will be continued until all outfalls are mapped town wide.

In 2007 some new development areas of the Town were mapped to continue the process.

In 2010 the town inspected new outfalls in the newer developments and have GIS located these outfalls for inclusion on the Town outfall Map.

3. Illicit Discharge and Elimination Program

Goal: Continue sampling of six selected outfalls. Start sampling outfalls for ecoli to determine TMDL contribution from other outfalls.

Working with NYE, the Town selected six outfalls (two residential, two industrial, and two commercial) to be sampled and tested. These six outfalls were sampled according to the DEP's requirements during the past summer and the results are included in this report.

In 2009 the Town did not sample any additional outfalls for ecoli to determine TMDL but will plan to do this in 2010.

The Town discovered and eliminated an illicit discharge on South Main St.

4. Future Illicit Discharge Detection and Elimination

Goal: Address and enforce future non-stormwater discharges

The Town during the mapping process reviews each outfall and collects data on the condition of the stormwater discharges as observed. This information is being reviewed and the Town will investigate any suspect reports of illicit discharges.

The Town has written an Illicit Discharge Detection and Elimination Manual for distribution and training purposes.

In 2010 the Town did perform some illicit discharge inspections in the new development areas and some of the older developments.

In October 2013 the Town inspected twenty streets, including all catch basins and outfalls for illicit discharge. None were found in this inspection.

In October 2014 the Town inspected twelve streets, including catch basins and outfalls for illicit discharge and not were discovered. In anticipation of the new General Permit the town approved roads were updated and confirmed with a count of catch basins included for each street. Detention ponds and outfalls will also be reviewed moving forward in 2015.

Section 4: Construction Site Stormwater Runoff Control

1. Requirements and Guidelines for Erosion and Sediment Controls

Goal: Implement and enforce the ordinance.

In early 2006 the Town's Board of Selectmen passed a "Stormwater Management Ordinance" and assigned responsibility for enforcement to the Town's Inland Wetlands and Watercourses Commission its agents and the Town Engineer.

The Town has stepped up both its initial review of any new or purposed construction projects and continues enforcement inspections of active projects to ensure erosion and sediment controls are in accordance with all local, state and federal regulations.

2. Procedures for Notifying Construction Site Developers and Operators of Requirements for Registration

Goal: Implement Town forms and makes the proper registration a condition of agency approvals for sites exceeding the 1- acre threshold

The Town continues to comply with all requirements of the General Permit for the Discharge of Stormwater and Dewatering Wastewaters Associated with Construction Activities.

3. Requirements for Construction Site Operators to Implement Appropriate Erosion and Sediment Control Best Management Practices

Goal: Continue requirements for construction site operators to implement appropriate erosion and sediment control best management practices

Planning & Zoning and Inland Wetland Agency enforcement inspections continue to ensure that all applicable regulations concerning the use of erosion and sediment control measures are followed.

4. Requirements for Construction Site Operators to Control Waste at the Site

Goal: Continue requirements for construction site operators to control waste at the site

Planning & Zoning and Inland Wetland Agency enforcement inspections currently ensure that all applicable regulations concerning waste control are followed.

5. Procedures for Site Plan Review

Goal: Continue site plan review procedures

The Town Engineer reviews all site plans for conformance to the Town's, state and federal requirements relating to construction site runoff control.

6. Procedures for Receipt and Consideration of Information Submitted by the Public

Goal: Continue procedures for receipt and consideration of information submitted by the public.

Information submitted by the public is forwarded to the appropriate Town department for consideration.

7. Procedures for Site Inspection and Enforcement of Control Measures

Goal: Continue site inspection and enforcement of control measures

Site inspection and enforcement of control measures are utilized on all of the Town's projects. Under the new ordinance there are three levels of Town enforcement. Initially the inspector issues a "Notice of Inspection" for corrections to any deficiencies. This is followed with a "Notice of Deficiency" with set time requirements for correction of any issues. This may be used up to two times. Sites which continue to be noncompliant are issued a "Cease and Desist Order" with penalty and must stop work and bring the site into compliance before proceeding.

The Town inspectors issued twelve Notice of Inspections and three Notice of Deficiencies to developers for soil and erosion control inspections in 2010. The issues identified in these inspections were corrected and this process will continue until construction is complete and the sites are stabilized.

Section 5: Post Construction Site Runoff Control

1. Requirements for Structural and Non-Structural BMPs

Goal: Continue implementation of BMPs including projects with greater than or equal to 1- acre in disturbance area

The Town Engineer currently reviews plans to evaluate stormwater discharges and the methods that may be used for the treatment of stormwater before it reaches an outlet.

2. Procedures for Addressing Post Construction Runoff from Construction and Reconstruction Projects

Goal: Continue procedures for addressing post construction runoff from construction and reconstruction projects with greater than or equal to 1-acre in disturbance area

An internal memorandum issued to all Town departments requires stormwater management BMPs for all projects.

3. Ensuring Long Term Operation and Maintenance of Best Management Practices

Goal: Continue operation and maintenance of BMPs

The Public Works Department is responsible for the long-term operation and maintenance of the Town's facilities.

In 2013 NYE in conjunction with the Town of Beacon Falls Inland Wetlands and Watercourses Commission inspected twenty-seven (27) detention ponds/basins and recommended correction action and persons responsible for any discrepancies found.

Section 6: Pollution Prevention / Good Housekeeping

1. Operation and Maintenance Program

Goal: Implement operation and maintenance requirements

The Town is continuing to identify the specifics of the training, record keeping, internal reporting, and maintenance that will be required as part of operation and maintenance plan related to stormwater management.

2. Employee Training Program

Goal: Develop employee-training curriculum

The Town Engineer has developed curriculum for training the subject material and will continue to conduct classes with those individuals that require training.

3. Street Sweeping Program

Goal: Implement street sweeping requirements.

The Public Works Department swept 32 miles of the Town's roadways and parking lots during the past year (2014).

4. Catch Basin Maintenance Program

Goal: Implement catch basin maintenance requirements

The Town's Public Works Department cleaned two hundred and sixty five (265) catch basins in 2014.

5. Preventative Maintenance Program

Goal: Implement preventative maintenance requirements

The Town conducts inspections as a part of new construction /reconstruction projects to identify existing drainage facilities that may be in need of repair or inadequate.

The Town conducts inspections as a part of new construction /reconstruction projects to identify existing drainage facilities that may be in need of repair or inadequate. During 2012, the Town installed 640ft of new drainage pipe with six new catch basins. The town also rebuilt six catch basins. In conjunction with potential upgrades to the Beacon Falls WWTF the Town is completed the I&I study of the sanitary sewer system in 2013 to determine and address cross connections or infiltration of stormwater.

3.0 Monitoring Data

Monitoring data for the 2014 year is included in Appendix I. Another round is schedule for early 2015 pending issuance of the new General Permit, which may change the sampling protocol.

4.0 Summary of Planned Stormwater Activities During the Next Reporting Cycle

Continued growth within the Town is being undertaken with an eye towards improving stormwater management. Developers who are working in areas where the existing stormwater infrastructure is not able to meet the needs of their planned construction are required to install or upgrade the stormwater infrastructure as part of their development.

The Public Works Department will continue its Preventative Maintenance Program. The Public Works Department and the Town Engineer will continue to map of the remainder of the Town's outfalls. The implemented ordinances and any changes in the re-issued General Permit will be review by the appropriate Town's Commission.

Continued training will be performed within the appropriate Town Departments and Commissions.

5.0 Changes In Any Identified Measurable Goals or Implementation Dates

The Town will continue to work towards meeting all of the deadlines as specified in the updated Stormwater Management Plan. Any delays in meeting the requirements of the plan will be identified and fixed within the constraints of the workloads of the various Town Departments and the Town budget.

I have personally examined and am familiar with the information submitted in this document and all attachments thereto, and I certify that, based on reasonable investigation, including my inquiry of those individuals responsible for obtaining the information, the submitted information is true, accurate and complete to the best of my knowledge and belief.

Christopher B. Biel
Signature of CEO/PEO or designee

Date: 1/7/15

Christopher B. Biel
Name of CEO/PEO or designee

First Selectman
Title

Prepared By:
Nafis and Young Engineers, Inc.

Lawrence K. Secor
Signature of Preparer

Date: 1/07/2014

Lawrence K. Secor, CHMM
Name of Preparer

Senior Environmental Project Manager
Title

APPENDIX I

STORMWATER MONITORING REPORTS



General Permit for the Discharge of Stormwater from Small Municipal Separate Storm Sewer Systems

Stormwater Monitoring Report Form

Please send completed form to: STORMWATER GROUP
BUREAU OF MATERIALS MANAGEMENT & COMPLIANCE ASSURANCE
DEPARTMENT OF ENVIRONMENTAL PROTECTION
79 ELM STREET
HARTFORD, CT 06106-5127

PERMITTEE INFORMATION

Town: <u>Beacon Falls</u>	
Mailing Address: <u>10 Maple Ave., Beacon Falls, CT 06403</u>	
Contact Person: <u>Robert Pruzinsky</u>	Title: <u>Road Foreman</u>
Phone: <u>203.729.6978</u>	Permit Registration #GSM: <u>0000065</u>


SAMPLING INFORMATION

Discharge Location (Lat/Long or other description): <u>NAD 83: 41° 26' 24" N, 073° 03' 39" W (C-1)</u>	
Please check the appropriate area description: <input type="checkbox"/> Industrial <input checked="" type="checkbox"/> Commercial <input type="checkbox"/> Residential	
Receiving Water (name, basin): <u>Naugatuck River, 6900</u>	
Time of Start of Discharge: <u>03:45 AM</u>	
Date/Time Collected: <u>04/30/2014, 09:09</u>	Water Temperature: <u>12.8 C</u>
Person Collecting Sample: <u>L. Secor</u>	
Storm Magnitude (inches): <u>1.14"</u>	Storm Duration (hours): <u>20</u>
Date of Previous Storm Event: <u>04/26/2014</u>	

MONITORING RESULTS

Parameter	Method	Results (units)	Laboratory
Sample pH	SM 5400-H+ B	6.4 (S.U.)	CT TESTING LABORATORIES, INC.
Rain pH	CP-p20	4.60 (S.U.)	FIELD
Hardness	2340 B	5 (mg/L)	CT TESTING LABORATORIES, INC.
Conductivity	2510B	21 (µmhos/cm)	CT TESTING LABORATORIES, INC.
Oil & Grease	1664 A	ND (<5.0 mg/L)	CT TESTING LABORATORIES, INC.
COD	410.4	45 (mg/L)	CT TESTING LABORATORIES, INC.
Turbidity	180.1	49 (NTU)	CT TESTING LABORATORIES, INC.
TSS	2504D	76 (mg/L)	CT TESTING LABORATORIES, INC.
TP	365.3	0.16 (mg/L)	CT TESTING LABORATORIES, INC.
Ammonia	350.1	ND 0.09 (mg/L)	CT TESTING LABORATORIES, INC.
TKN	351.2	0.8 (mg/L)	CT TESTING LABORATORIES, INC.
NO ₃ +NO ₂	4500-NO3 F	0.2 (mg/L)	CT TESTING LABORATORIES, INC.
E. coli	9222B/9222G	800 (/100ml)	CT TESTING LABORATORIES, INC.

STATEMENT OF ACKNOWLEDGMENT

I certify that the data reported on this document were prepared under my direction or supervision in accordance with the MS4 General Permit. The information submitted is, to the best of my knowledge and belief, true, accurate and complete.	
Authorized Official: <u>Christopher Bielik, First Selectman</u>	
Signature: <u></u> (Print Name)	Date: <u>5/22/14</u>



General Permit for the Discharge of Stormwater from Small Municipal Separate Storm Sewer Systems

Stormwater Monitoring Report Form

Please send completed form to: STORMWATER GROUP
BUREAU OF MATERIALS MANAGEMENT & COMPLIANCE ASSURANCE
DEPARTMENT OF ENVIRONMENTAL PROTECTION
79 ELM STREET
HARTFORD, CT 06106-5127

PERMITTEE INFORMATION

Town: <u>Beacon Falls</u>	
Mailing Address: <u>10 Maple Ave., Beacon Falls, CT 06403</u>	
Contact Person: <u>Robert Pruzinsky</u>	Title: <u>Road Foreman</u>
Phone: <u>203.729.6978</u>	Permit Registration #GSM: <u>0000065</u>


SAMPLING INFORMATION

Discharge Location (Lat/Long or other description): <u>NAD 83: 41° 26' 13" N, 073° 03' 35" W (C-2)</u>	
Please check the appropriate area description: <input type="checkbox"/> Industrial <input checked="" type="checkbox"/> Commercial <input type="checkbox"/> Residential	
Receiving Water (name, basin): <u>Naugatuck River, 6900</u>	
Time of Start of Discharge: <u>03:45 AM</u>	
Date/Time Collected: <u>04/30/2014, 08:58</u>	Water Temperature: <u>13.6 C</u>
Person Collecting Sample: <u>L. Secor</u>	
Storm Magnitude (inches): <u>1.14"</u>	Storm Duration (hours): <u>20</u>
Date of Previous Storm Event: <u>04/26/2014</u>	

MONITORING RESULTS

Parameter	Method	Results (units)	Laboratory
Sample pH	SM 5400-H+ B	6.2 (S.U.)	CT TESTING LABORATORIES, INC.
Rain pH	CP-pH20	4.60 (S.U.)	FIELD
Hardness	2340 B	2 (mg/L)	CT TESTING LABORATORIES, INC.
Conductivity	2510B	16 (µmhos/cm)	CT TESTING LABORATORIES, INC.
Oil & Grease	1664 A	ND (<5.0 mg/L)	CT TESTING LABORATORIES, INC.
COD	410.4	12 (mg/L)	CT TESTING LABORATORIES, INC.
Turbidity	180.1	11.0 (NTU)	CT TESTING LABORATORIES, INC.
TSS	2504D	24 (mg/L)	CT TESTING LABORATORIES, INC.
TP	365.3	0.10 (mg/L)	CT TESTING LABORATORIES, INC.
Ammonia	350.1	0.09 (mg/L)	CT TESTING LABORATORIES, INC.
TKN	351.2	0.41 (mg/L)	CT TESTING LABORATORIES, INC.
NO ₃ +NO ₂	4500-NO3 F	0.2 (mg/L)	CT TESTING LABORATORIES, INC.
E. coli	9222B/9222G	4,100 (/100ml)	CT TESTING LABORATORIES, INC.

STATEMENT OF ACKNOWLEDGMENT

I certify that the data reported on this document were prepared under my direction or supervision in accordance with the MS4 General Permit. The information submitted is, to the best of my knowledge and belief, true, accurate and complete.	
Authorized Official: <u>Christopher Bielik, First Selectman</u>	
Signature: <u></u>	Date: <u>5/22/14</u>



General Permit for the Discharge of Stormwater from Small Municipal Separate Storm Sewer Systems

Stormwater Monitoring Report Form

Please send completed form to: STORMWATER GROUP
BUREAU OF MATERIALS MANAGEMENT & COMPLIANCE ASSURANCE
DEPARTMENT OF ENVIRONMENTAL PROTECTION
79 ELM STREET
HARTFORD, CT 06106-5127

PERMITTEE INFORMATION

Town: <u>Beacon Falls</u>	
Mailing Address: <u>10 Maple Ave., Beacon Falls, CT 06403</u>	
Contact Person: <u>Robert Pruzinsky</u>	Title: <u>Road Foreman</u>
Phone: <u>203.729.6978</u>	Permit Registration #GSM: <u>0000065</u>


SAMPLING INFORMATION

Discharge Location (Lat/Long or other description): <u>NAD 83: 41° 25' 49" N, 073° 04' 36" W (I-1)</u>	
Please check the appropriate area description: <input checked="" type="checkbox"/> Industrial <input type="checkbox"/> Commercial <input type="checkbox"/> Residential	
Receiving Water (name, basin): <u>Naugatuck River, 6900</u>	
Time of Start of Discharge: <u>03:45 AM</u>	
Date/Time Collected: <u>04/30/2014, 09:59</u>	Water Temperature: <u>12.9 C</u>
Person Collecting Sample: <u>L Secor</u>	
Storm Magnitude (inches): <u>1.14"</u>	Storm Duration (hours): <u>20</u>
Date of Previous Storm Event: <u>04/26/2014</u>	

MONITORING RESULTS

Parameter	Method	Results (units)	Laboratory
Sample pH	SM 5400-H+ B	6.6 (S.U.)	CT TESTING LABORATORIES, INC.
Rain pH	CP-pH20	4.60 (S.U.)	FIELD
Hardness	2340 B	21 (mg/L)	CT TESTING LABORATORIES, INC.
Conductivity	2510B	96 (µmhos/cm)	CT TESTING LABORATORIES, INC.
Oil & Grease	1664 A	ND (<5.0 mg/L)	CT TESTING LABORATORIES, INC.
COD	410.4	ND (<4.0 (mg/L)	CT TESTING LABORATORIES, INC.
Turbidity	180.1	1.9 (NTU)	CT TESTING LABORATORIES, INC.
TSS	2504D	1 (mg/L)	CT TESTING LABORATORIES, INC.
TP	365.3	0.02 (mg/L)	CT TESTING LABORATORIES, INC.
Ammonia	350.1	0.15 (mg/L)	CT TESTING LABORATORIES, INC.
TKN	351.2	0.33 (mg/L)	CT TESTING LABORATORIES, INC.
NO ₃ +NO ₂	4500-NO3 F	0.2 (mg/L)	CT TESTING LABORATORIES, INC.
E. coli	9222B/9222G	1,500 (/100ml)	CT TESTING LABORATORIES, INC.

STATEMENT OF ACKNOWLEDGMENT

I certify that the data reported on this document were prepared under my direction or supervision in accordance with the MS4 General Permit. The information submitted is, to the best of my knowledge and belief, true, accurate and complete.	
Authorized Official: <u>Christopher Bielik, First Selectman</u>	
Signature: <u></u>	Date: <u>5/22/14</u>



General Permit for the Discharge of Stormwater from Small Municipal Separate Storm Sewer Systems

Stormwater Monitoring Report Form

Please send completed form to: STORMWATER GROUP
BUREAU OF MATERIALS MANAGEMENT & COMPLIANCE ASSURANCE
DEPARTMENT OF ENVIRONMENTAL PROTECTION
79 ELM STREET
HARTFORD, CT 06106-5127

PERMITTEE INFORMATION

Town: <u>Beacon Falls</u>
Mailing Address: <u>10 Maple Ave. Beacon Falls, CT 06403</u>
Contact Person: <u>Robert Pruzinsky</u> Title: <u>Road Foreman</u>
Phone: <u>203.729.6978</u> Permit Registration #GSM: <u>0000065</u>


SAMPLING INFORMATION

Discharge Location (Lat/Long or other description): <u>NAD 83: 41° 25' 59" N, 073° 03' 47" W (I-2)</u>	
Please check the appropriate area description: <input checked="" type="checkbox"/> Industrial <input type="checkbox"/> Commercial <input type="checkbox"/> Residential	
Receiving Water (name, basin): <u>Naugatuck River, 6900</u>	
Time of Start of Discharge: <u>03:45 AM</u>	
Date/Time Collected: <u>04/30/2014, 09:19</u>	Water Temperature: <u>12.8 C</u>
Person Collecting Sample: <u>L. Secor</u>	
Storm Magnitude (inches): <u>1.14"</u>	Storm Duration (hours): <u>20</u>
Date of Previous Storm Event: <u>04/26/2014</u>	

MONITORING RESULTS

Parameter	Method	Results (units)	Laboratory
Sample pH	SM 5400-H+ B	5.3 (S.U.)	CT TESTING LABORATORIES, INC.
Rain pH	CP pH20	4.60 (S.U.)	FIELD
Hardness	2340 B	ND (<2 mg/L)	CT TESTING LABORATORIES, INC.
Conductivity	2510B	10 (µmhos/cm)	CT TESTING LABORATORIES, INC.
Oil & Grease	1664 A	ND (<5.0mg/L)	CT TESTING LABORATORIES, INC.
COD	410.4	11 (mg/L)	CT TESTING LABORATORIES, INC.
Turbidity	180.1	5.7 (NTU)	CT TESTING LABORATORIES, INC.
TSS	2504D	9 (mg/L)	CT TESTING LABORATORIES, INC.
TP	365.3	0.03 (mg/L)	CT TESTING LABORATORIES, INC.
Ammonia	350.1	0.1 (mg/L)	CT TESTING LABORATORIES, INC.
TKN	351.2	0.32 (mg/L)	CT TESTING LABORATORIES, INC.
NO ₃ +NO ₂	4500-NO3 F	0.2 (mg/L)	CT TESTING LABORATORIES, INC.
E. coli	9222B/9222G	200 (/100ml)	CT TESTING LABORATORIES, INC.

STATEMENT OF ACKNOWLEDGMENT

I certify that the data reported on this document were prepared under my direction or supervision in accordance with the MS4 General Permit. The information submitted is, to the best of my knowledge and belief, true, accurate and complete.	
Authorized Official: <u>Christopher Bielik, First Selectman</u>	
Signature: <u></u>	Date: <u>5/22/14</u>



General Permit for the Discharge of Stormwater from Small Municipal Separate Storm Sewer Systems

Stormwater Monitoring Report Form

Please send completed form to: STORMWATER GROUP
BUREAU OF MATERIALS MANAGEMENT & COMPLIANCE ASSURANCE
DEPARTMENT OF ENVIRONMENTAL PROTECTION
79 ELM STREET
HARTFORD, CT 06106-5127

PERMITTEE INFORMATION

Town: Beacon Falls

Mailing Address: 10 Maple Ave., Beacon Falls, CT 06403

Contact Person: Robert Pruzinsky

Title: Road Foreman

Phone: 203.729.6978

Permit Registration #GSM: 0000065

SAMPLING INFORMATION

Discharge Location (Lat/Long or other description): NAD 83: 41° 26' 15" N, 073° 04' 14" W (R-1)

Please check the appropriate area description: ☐ Industrial ☐ Commercial ☒ Residential

Receiving Water (name, basin): Naugatuck River, 6900

Time of Start of Discharge: 03:45

Date/Time Collected: 04/30/2014, 09:49

Water Temperature: 11.4 C

Person Collecting Sample: L. Secor

Storm Magnitude (inches): 1.14"

Storm Duration (hours): 20

Date of Previous Storm Event: 04/26/2014

MONITORING RESULTS

Parameter	Method	Results (units)	Laboratory
Sample pH	SM 5400-H+ B	6.2 (S.U.)	CT TESTING LABORATORIES, INC.
Rain pH	CP-pH20	4.60 (S.U.)	FIELD
Hardness	2340 B	31 (mg/L)	CT TESTING LABORATORIES, INC.
Conductivity	2510B	119 (µmhos/cm)	CT TESTING LABORATORIES, INC.
Oil & Grease	1664 A	ND (<5.0mg/L)	CT TESTING LABORATORIES, INC.
COD	410.4	9 (mg/L)	CT TESTING LABORATORIES, INC.
Turbidity	180.1	4.5 (NTU)	CT TESTING LABORATORIES, INC.
TSS	2504D	45 (mg/L)	CT TESTING LABORATORIES, INC.
TP	365.3	0.08 (mg/L)	CT TESTING LABORATORIES, INC.
Ammonia	350.1	0.13 (mg/L)	CT TESTING LABORATORIES, INC.
TKN	351.2	0.64 (mg/L)	CT TESTING LABORATORIES, INC.
NO ₃ +NO ₂	4500-NO3 F	1.4 (mg/L)	CT TESTING LABORATORIES, INC.
E. coli	9222B/9222G	ND <100 (/100ml)	CT TESTING LABORATORIES, INC.

STATEMENT OF ACKNOWLEDGMENT

I certify that the data reported on this document were prepared under my direction or supervision in accordance with the MS4 General Permit. The information submitted is, to the best of my knowledge and belief, true, accurate and complete.

Authorized Official: Christopher Bielik, First Selectman

Signature: (Print Name) Christopher Bielik

Date: 5/22/14



General Permit for the Discharge of Stormwater from Small Municipal Separate Storm Sewer Systems

Stormwater Monitoring Report Form

Please send completed form to: STORMWATER GROUP
BUREAU OF MATERIALS MANAGEMENT & COMPLIANCE ASSURANCE
DEPARTMENT OF ENVIRONMENTAL PROTECTION
79 ELM STREET
HARTFORD, CT 06106-5127

PERMITTEE INFORMATION

Town: <u>Beacon Falls</u>	
Mailing Address: <u>10 Maple Ave., Beacon Falls, CT 06403</u>	
Contact Person: <u>Robert Pruzinsky</u>	Title: <u>Road Foreman</u>
Phone: <u>203.729.6978</u>	Permit Registration #GSM: <u>0000065</u>


SAMPLING INFORMATION

Discharge Location (Lat/Long or other description): <u>NAD 83: 41° 26' 12" N, 073° 02' 33" W (R-2)</u>	
Please check the appropriate area description: <input type="checkbox"/> Industrial <input type="checkbox"/> Commercial <input checked="" type="checkbox"/> Residential	
Receiving Water (name, basin): <u>Naugatuck River, 6900</u>	
Time of Start of Discharge: <u>03:45 AM</u>	
Date/Time Collected: <u>04/30/2014, 09:19</u>	Water Temperature: <u>10.6 C</u>
Person Collecting Sample: <u>L. Secor</u>	
Storm Magnitude (inches): <u>1.14"</u>	Storm Duration (hours): <u>20</u>
Date of Previous Storm Event: <u>04/26/2014</u>	

MONITORING RESULTS

Parameter	Method	Results (units)	Laboratory
Sample pH	SM 5400-H+ B	5.9 (S.U.)	CT TESTING LABORATORIES, INC.
Rain pH	CP pH20	4.60 S.U.)	FIELD
Hardness	2340 B	3 (mg/L)	CT TESTING LABORATORIES, INC.
Conductivity	2510B	14 (µmhos/cm)	CT TESTING LABORATORIES, INC.
Oil & Grease	1664 A	ND (<5.0 mg/L)	CT TESTING LABORATORIES, INC.
COD	410.4	15 (mg/L)	CT TESTING LABORATORIES, INC.
Turbidity	180.1	17.1 (NTU)	CT TESTING LABORATORIES, INC.
TSS	2504D	70 (mg/L)	CT TESTING LABORATORIES, INC.
TP	365.3	0.09 (mg/L)	CT TESTING LABORATORIES, INC.
Ammonia	350.1	0.06 (mg/L)	CT TESTING LABORATORIES, INC.
TKN	351.2	0.53 (mg/L)	CT TESTING LABORATORIES, INC.
NO ₃ +NO ₂	4500-NO3 F	ND < 0.1 (mg/L)	CT TESTING LABORATORIES, INC.
E. coli	9222B/9222G	2,200 (/100ml)	CT TESTING LABORATORIES, INC.

STATEMENT OF ACKNOWLEDGMENT

I certify that the data reported on this document were prepared under my direction or supervision in accordance with the MS4 General Permit. The information submitted is, to the best of my knowledge and belief, true, accurate and complete.	
Authorized Official: <u>Christopher Bielik, First Selectman</u>	
Signature: <u></u>	Date: <u>5/22/14</u>

APPENDIX II

STORMWATER BMPS, OUTREACH EXAMPLES and REPORTS



How do I Dispose of.....



Light Bulbs

Compact fluorescent light bulbs (CFLs) can be recycled at home improvement stores such as Lowes and Home Depot. CFLs and fluorescent tubes may be accepted at your local transfer station



Oil-Based Paint

Oil based paints, stains, primers, sealers, thinners and aerosols can be disposed of at HHW collections, participating transfer stations, and paint retail stores. To find a paint drop-off location near you, visit : <http://www.paintcare.org/locator/index.php>



Latex Paint

Connecticut began a statewide paint recycling program In July 2013. Latex paint will now be accepted at HHW collections, participating transfer stations and paint retail stores. To find a paint drop-off location near you, visit : <http://www.paintcare.org/locator/index.php>



Batteries

Rechargeable batteries can be recycled at electronics retailers, home improvement stores, transfer stations, and HHW collections. Alkaline batteries are not considered hazardous and can be disposed of in the regular trash. Car batteries can be brought to your local transfer station or any retailer who sells automotive batteries in the state.



Household Cleaners

Household cleaners such as bleach, disinfectants, kitchen/bathroom cleaners, detergents, waxes, and polishes can be disposed of at HHW collections.



Automotive Products

Automotive products such as fuel additives, break and rust solvents, engine cleaners, gasoline and diesel fuel, Freon, brake fluid, and antifreeze can be disposed of at HHW collections.



Mercury-Containing Products

Mercury-containing products such as thermometers, thermostats, pressure measuring devices, electrical switches, and light sensors can be disposed of at HHW collections.



Lawn and Garden Products

Lawn and garden products such as pesticides, insecticides, fertilizers, herbicides, flea/tick spray, and pool chemicals can be disposed of at HHW collections.



Prescription Medications

Do NOT flush medications down the toilet or sink. This causes pollution and effects drinking water and wildlife. Contact your local pharmacy or police department about drug take-back programs in your area.



Fire Extinguishers

Most new fire extinguishers can be recharged. Older fire extinguishers may contain carbon tetrachloride and should be brought to HHW collections. Contact your local transfer station or fire department to see if they accept empty fire extinguishers



Propane Grill Tanks

Propane grill tanks can be recycled or exchanged for a small fee at gas and propane companies, Walmart, Lowes, Stop & Shop, Walgreens, and other local retailers. Contact your local transfer station to see if they accept EMPTY propane cylinders for recycling. Ensure the cylinder is EMPTY by operating with an appliance until the flame is extinguished.



Oversized Items

Contact your local transfer station to see if your town or city collects oversize items such as mattresses, furniture, and rugs.



Electronics

Electronic devices such as TVs, computers, CRT monitors, and printers can be recycled at your local transfer station. Contact your local recycling coordinator for more information. Major retailers, like Best Buy and Target, also accept cell phones and other small electronic devices at no charge.



Motor Oil

Motor oil can be disposed of at your local transfer station. Service stations may also accept motor oil. Motor oil is not accepted at HHW collections

**For More Information
Contact Your Local Transfer Station**



COUNCIL of GOVERNMENTS
CENTRAL NAUGATUCK VALLEY

TOWN OF BEACON FALLS
10 MAPLE AVE
BEACON FALLS, CT 06403-1114

9094

Client #: 994030
Invoice #: DEP242355
Invoice Date: 12/09/2014
Payment Due Date: 01/01/2015
Invoice Amount: \$187.50
Terms: Net 30 @ 15.00%; Initial
Penalty: 10.00%; Minimum
Penalty: \$18.75;

Billing Details


Rev. ID	Reference #	Description	Fee Amt	Qty	Disc./Adj.	Amount Due
713	Permit #: GSM000065	Stormwater Permits - Plan Review, GSM, Stormwater Plan For MS4 (Due Every January), NPDES	187.50	1	0.00	\$187.50

BEACON FALLS, TOWN OF, MS4 PERMIT,
BEACON FALLS, CT 06403
Stormwater MS4 annual plan review fee

Current Charges:

\$187.50 ✓

Client Outstanding Balance Owed to DEEP (prior to current invoice) \$0.00



Please contact DEEP Accounts Receivable Office at (860) 424-4004 to request a detailed Statement of Outstanding charges.

STREET DEPT.
LINE # 10-90-59-1720
P/O # _____
DATE 12/16/14 12/29/14
APPROVED [Signature] dce

12-31-14
CHECK NO. 17073

Invoice #: DEP242355

Printed On: 12/09/2014