



TOWN OF
BEACON FALLS
CONNECTICUT

WPCF

Monthly Report

June 2023 Meeting / May 2023 Data

Total Flow (RAW SEWAGE) :	12,634,000 gals.	Beacon Heights Leachate
Total Septage Received :	10,000 gals.	May 645,604 gals.
Total Sludge Removed :	158,600 gals.	
Beacon Heights Leachate :	601,748 gals. (April)	
Total Phosphorous Discharged :	2.69 lbs./day	
Total Nitrogen Discharged :	36 lbs./day	

*** Attached is a photo of the finished digester cover ***

EMERGENCY CALLS & ALARMS :

None to report

Repair or Replacement :

5-17 Digester job started with the removal of the floating cover

5-18 & 19 Construction of the new fixed roof

5-22 Birmingham Construction began fixing the sewer defects found on Avenue E ext. , E , Feldspar and Rt. 42

On going:

SLR engineering is working on the RFP for the electrical upgrade at the WPCF

Heavy flows at the beginning of the month have given us problems with sludge settleability and nitrogen removal, it has been a constant battle trying to keep the plant in check.

Sewer inspections:

5-1 Lot # 193 Chatfield Farms

5-18 13 Ave B

5-26 Lot # 226 Chatfield Farms

Meetings / Classes :

5-2 Pre-Bid meeting for sewer repairs in the Avenues section

5-22 on-site meeting with Birmingham Construction and Luchs Engineering to go over ground rules for the sewer work being done at the Avenues section.

*Thank you,
For letting me serve.*

*Thomas A. Carey
WPCF Superintendent*