




Town of Beacon Falls Office of the Fire Marshal



10 Maple Ave
Beacon Falls, CT 06403
(475) 777-6020

Fire Marshal Brian DeGeorge
Deputy Fire Marshal Cal Brennan

Gerry Smith
First Selectman
10 Maple Ave
Beacon Falls, CT 06403

July 7, 2022

First Selectman Smith,

Below is a report from the Fire Marshal's Office for the Month of June.

- 2 Alliance Circle- Annual Inspection
- 149 Old Turnpike Rd- Pre-inspection
- 2 North Main St- Progress check
- 125 South Main St- Walk through
- 170 Pinesbridge Rd- Sprinkler system malfunction- FD report-faulty backflow switch
- 105 Breault Rd- Annual Inspection
- 105A Breault Rd- Annual inspection
- 2 North Main St, Unit B211- Temp wiring concern-called to location by property manager
- 127 Pinesbridge Rd- Knox Box
- 3 Havilland Drive- Annual Inspection
- 170 Pinesbridge Rd- Alarm follow up
- 113 South Main St- Annual Inspection
- 170 Pinesbridge Rd- Alarm Meeting
- 158 Pinesbridge Rd- Meeting with sprinkler company
- Laurel Ledge Elementary- Kitchen Review
- 1 CO Detector Install
- 1 Smoke Detector Install
- Open burn official recertification
- Restocked Smoke/CO detectors at Ace Hardware



Town of Beacon Falls Office of the Fire Marshal



10 Maple Ave
Beacon Falls, CT 06403
(475) 777-6020
Fire Marshal Brian DeGeorge
Deputy Fire Marshal Cal Brennan

Any questions or concerns please contact me directly.

Respectfully,

A handwritten signature in black ink, consisting of a stylized initial 'B' followed by a long horizontal line.

Fire Marshal
Brian DeGeorge