



TOWN OF

# BEACON FALLS

CONNECTICUT

## WPCF

### Monthly Report

June 2020 Meeting / May 2020 Data

Total Flow (RAW SEWAGE) :	12,593,300 gals.	Beacon Heights Leachate
Total Septage Received :	13,600 gals.	
Total Sludge Removed :	146,400 gals.	
Beacon Heights Leachate :	491,535 gals.	
Total Phosphorous Discharged :	3.03 lbs./day	
Total Nitrogen Discharged :	62.75 lbs./day	

#### EMERGENCY CALLS & ALARMS :

5-5 RAS high float alarm WPCF  
5-21 Burglar alarm West Rd P.S  
5-28 Odor complaint / Hockanum Glen Dr  
5-31 RAS high float alarm WPCF

#### Repair or Replacement :

5-4 Rebuilt and installed #1 WPCF RAS pump  
5-13 Installed a gate and safety sign at bottom of stairs leading to the roof of the WPCF building

#### Misc.:

Annual calibrations were preformed on WPCF flow meters  
Our PACL chemical hold tanks are showing a build-up of sediment, we have implemented a full clean-out after each use.  
5-20 Started draining #1 aeration tank.  
5-28 Put # 1 AT on -line and took # 2 AT off-line.

#### Ongoing :

5-28 Knapp engineering / SCADA work

#### Meetings / Classes :

All classes canceled

*Thank you,  
For letting me serve.*

*Thomas A. Carey  
WPCF Superintendent*

