# **WPCF Monthly Report**

January 2020 Meeting / December 2019 Data

Total Flow (RAW SEWAGE):

13,528,400 gals.

Beacon Heights Leachate

Total Septage Received:

7,250 gals.

369,496

Total Sludge Removed:

111,400 gals.

October November 723,064

Beacon Heights Leachate:

782,995 gals.

782,995 December

Total Phosphorous Discharged:

8.38 lbs./day

Total Nitrogen Discharged:

85 lbs./day

4th Quarter total

1,875,555 Gallons

# **EMERGENCY CALLS & ALARMS:**

12-5 called out to Buckingham St. to clean sewer invert, it was blocked with dirt from being knocked off it's base with a plow. 12-14,15 28 Pines bridge high current alarm pump #1.

12-15 Pines bridge sump pump malfunction.

## Repair or Replacement:

## Testing:

Had sludge sample sent out to be compliant with new sludge hauler (Synagro).

### Misc.:

We were short handed for most of the month do to the Holiday season and the birth of Ryan's second daughter.

12-10 Drained and cleaned primary tank.

12-2,3,17 snow detail.

#### Ongoing:

Preparing for a trial run with a new product UNLR which removes phosphorus.

Working with Kovacs & McVac to see when we can get our digester job started.

For the past month we have been dealing with excessive foam in our aeration tanks and troughs.

## Meetings / Classes:

12-3 Steve attended a waste water class

12-4,11,18 & 26 Tom attended waste water classes

Thank you, For letting me serve.

Thomas A. Carey WPCF Superintendent