



TOWN OF

BEACON FALLS

CONNECTICUT

WPCF Monthly Report

May 2022 Meeting / April 2022 Data

Total Flow (RAW SEWAGE) : 13,179,100 gals.
Total Septage Received : 10,250 gals.
Total Sludge Removed : 176900 gals.
Beacon Heights Leachate : No Data gals.
Total Phosphorous Discharged : 1.97 lbs./day
Total Nitrogen Discharged : 31 lbs./day

Beacon Heights Leachate

EMERGENCY CALLS & ALARMS :

4-3,4-15 West rd. pump station alarms
4-8 WPCF blower alarm

Repair or Replacement :

4-4 West rd. pumpstation , one of the two pumps had to be pulled and the bottom plate had to be adjusted
4-20 Pulled 2 raw sewage pumps this month at the Plant one of them just needed to derigged and we replaced the other with a rebuilt one.
4-29 Railroad ave. pumpstation Ras sewage pumps were pulled cleaned and inspected

Testing :

2nd quarter ATMR samples were sent out for analysis

Misc.:

4-3 All-State scale calibrated our scale in the lab
4-25 WPCF flow meters and recorders were calibrated

Ongoing :

4-7,4-21 and 4-28 cleaned contact tank at treatment plant
House keeping in WPCF basement

Meetings / Classes :

2-28 Steve has started classes in preparation to sit for his class III license

*Thank you,
For letting me serve.*

*Thomas A. Carey
WPCF Superintendent*