



**WPCF
Monthly Report**

March 2022 Meeting / February 2022 Data

Total Flow (RAW SEWAGE) :	10,068,500 gals.	Beacon Heights Leachate
Total Septage Received :	1,000 gals.	
Total Sludge Removed :	134,200 gals.	
Beacon Heights Leachate :	403,200 gals.	
Total Phosphorous Discharged :	6.65 lbs./day	
Total Nitrogen Discharged :	40 lbs./day	

EMERGENCY CALLS & ALARMS :

2-15 RAS / PAC alarm at Treatment plant.
2-16 Mike from Knapp onsite trouble shooting blowers and SCADA.
2-18 West Rd pump station power loss.

Repair or Replacement :

2-18 The flights in the west secondary stopped working. A faulty transformer was replaced by W J electric.
2-22 New BPS alarm antennas were installed.

Testing :

2-2 SLR Pines bridge Pump station drawdown (flow test).

Misc.:

2-7 Eversource onsite for electrical upgrade.
2-13,2-25 Snow detail.

Ongoing :

Digester roof and Electrical upgrade

Meetings / Classes :

2-8 Virtual Budget Workshop.

*Thank you,
For letting me serve.*

*Thomas A. Carey
WPCF Superintendent*