



TOWN OF

BEACON FALLS

CONNECTICUT

WPCF Monthly Report

September 2022 Meeting / August 2022 Data

Total Flow (RAW SEWAGE) :	7,711,800 gals.	Beacon Heights Leachate
Total Septage Received :	13,750 gals.	
Total Sludge Removed :	146,400 gals.	
Beacon Heights Leachate :	No Data gals.	
Total Phosphorous Discharged :	1.92 lbs./day	
Total Nitrogen Discharged :	24 lbs./day	

EMERGENCY CALLS & ALARMS :

None to report

Repair or Replacement :

Magnawind has been to the WPCF a few times this month troubleshooting our blower control panel.
blower #2 will not run in auto.

8-5 Our phone and time clock at the plant are working again. Comcast had disabled the lines, not sure why. (2 MONTHS)

8-12 The diffusers in aeration tank #3 are installed and the tank is filled. All four tanks have new diffusers now.

Testing :

8-1 The WPCF discharged only 12lbs of Nitrogen in its effluent, this is a first for the plant. Historically it has never met permit.

Misc.:

8-10 Cut brush between solar panels, along roadway

Working on safety violations.

On Gaurd Fence company on-site for quote.

Ongoing :

Working on safety violations.

Meetings / Classes :

None to report

*Thank you,
For letting me serve.*

*Thomas A. Carey
WPCF Superintendent*