



TOWN OF

BEACON FALLS

CONNECTICUT

WPCF Monthly Report

July 2022 Meeting / June 2022 Data

Total Flow (RAW SEWAGE) : 8,624,900 gals.
Total Septage Received : 11,000 gals.
Total Sludge Removed : 231,800 gals.
Beacon Heights Leachate : No Data gals.
Total Phosphorous Discharged : 2.37 lbs./day
Total Nitrogen Discharged : 26 lbs./day

Beacon Heights Leachate
No Data

EMERGENCY CALLS & ALARMS :
No Calls

Repair or Replacement :

6-3 Knapp Eng. ? Trouble shoot, SCADA won't call out

Started working on changing the bladders in the #3 aeration tank. #3 tank is the last one to be equip with new bladders.
pulled pump at Pines bridge pump station and deragged.

Testing :

OSHA preformed noise monitoring on Ryan as he operated the lawn mower

Misc.:

6-21 & 6-28 OSHA rep. on site

6-8 Cleaned contact tank

Ongoing :

lawn mowing and weed wacking at all pump stations and Treatment plant.

Meetings / Classes :

* We need to meet and discuss which direction the Town would like to go on both the electrical upgrade and the digester job.

*Thank you,
For letting me serve.*

*Thomas A. Carey
WPCF Superintendent*

