



TOWN OF

BEACON FALLS

CONNECTICUT

WPCF Monthly Report

October 2022 Meeting / September 2022 Data

Total Flow (RAW SEWAGE) :	9,663,700 gals.	Beacon Heights Leachate
Total Septage Received :	11,000 gals.	
Total Sludge Removed :	109,800 gals.	
Beacon Heights Leachate :	No Data gals.	
Total Phosphorous Discharged :	No Data lbs./day	
Total Nitrogen Discharged :	No Data lbs./day	

EMERGENCY CALLS & ALARMS :

9-6 Heavy rain event WPCF overwhelmed and West Rd pump station lost power
9-7 #6 S.Cir. called in a sewer back-up.
9-14 CBYD for 17 Hockanum Glen / electrical issue

Repair or Replacement :

9-9 VFD problem fixed by Magnawind
9-12 Northeast generator did the minor PM for all four of our generators.
9-19 Installed a new motor on the east secondary flights

Testing :

9-18,20,22 annual Chronic test

Misc.:

9-12 Crane inspection company on site for quote.
9-26 American Rooter performed sewer cleaning on Church, Beacon, S Cir, Town Green, Main Stand our 3 barrel siphon which crosses the river.
9-28 Superior was hired for TV pipe inspection on Church, Beacon, S Cir, Town Green. More work needs to be done on Church.

Ongoing :

Working on OSHA violations

Meetings / Classes :

None to report

*Thank you,
For letting me serve.*

*Thomas A. Carey
WPCF Superintendent*

