

## WPCF **Monthly Report**

January 2023 Meeting / December 2022 Data

Total Flow (RAW SEWAGE) : 133,027,700 gals. **Total Septage Received :** 9,750 gals. **Total Sludge Removed :** 122,000 gals. Beacon Heights Leachate : 446,400 gals. **Total Phosphorous Discharged :** 7.90 lbs./day **Total Nitrogen Discharged :** 56 lbs./day

**Beacon Heights Leachate** 4th Quarter Totals October 506.459 November 440,921 December 446,400 Total 1,393,780 Gallons

**EMERGENCY CALLS & ALARMS :** 

12-12 snow detail 12-21 West Rd pump station power loss

**Repair or Replacement :** 

replaced a section on our truck loading sludge line

12-5 a new fence was installed around our grit pit

12-7 safety cages were installed around the WPCF influent pumps drive shafts

Testing : none to report

Misc.:

venders are being scheduled for flow meter demonstrations, we are going to have one installed on our sludge line

Ongoing :

12-8 cement work on the digester began

12-14 the concrete cap on the digester poured

Kovacs has taken all the parts needed to assemble the digester cover at their shop

12-16 Jeff Smith and I did some search around the NEJ site, we are still trying to figure out to cause of the by-pass from the private line that exits their property.

Meetings / Classes : Ryan attended a prep classes for his Class 3 exam 12-1, 8, 15 & 22 Employee handbook meeting canceled Monthly meeting with Gerard canceled Permit meeting: The WPCF has been assigned the duty of inspecting sewer connections and signing off on the permit

Thank yeu, 'For letting me serve. 'Thomas A. Carey WPC'F Superintendent