



TOWN OF

BEACON FALLS

CONNECTICUT

WPCF Monthly Report

February 2023 Meeting / January 2023 Data

Total Flow (RAW SEWAGE) :	14,716,700 gals.	Beacon Heights Leachate
Total Septage Received :	3,750 gals.	
Total Sludge Removed :	103,700 gals.	
Beacon Heights Leachate :	888,270 gals.	
Total Phosphorous Discharged :	7.37 lbs./day	
Total Nitrogen Discharged :	53 lbs./day	

EMERGENCY CALLS & ALARMS :

1-11 WPCF generator failed to start for it's weekly programed exercise, it was starving for fuel. The water/fuel separator was cracked and sucking air.

Repair or Replacement :

1-23 A new block heater was installed on the generator at the Pines bridge pump station.

1-31 Ober-Read serviced the blowers at the WPCF (annual preventative maintenance)

Testing :

1st quarter ATMR samples were sent out and passed

Misc.:

(scheduled) camera inspection of the sewer lines around the avenues prior to Aquarion installing new water main.

We are getting closer to go out to bid for the Electrical / generator upgrade, SLR is currently working on the Bid package.

Naugatuck is shutting down for maintenance on there incinerator , we hope to have the digester cleaned for our new roof job when they start back up.

Sewer inspections :

1-24 42 Rice Lane (passed)

1-25 94 Fieldstone - Lot 221 Chatfield Farms (passed)

Meetings / Classes :

1-20 I attended the CTWEA managers forum

*Thank you,
For letting me serve.*

*Thomas A. Carey
WPCF Superintendent*