



WPCF

Monthly Report

2020 Meeting / 2020 Data

Total Flow (RAW SEWAGE) :	11,946,700 gals.	Beacon Heights Leachate / Gallons
Total Septage Received :	8,750 gals.	January 473,974
Total Sludge Removed :	128,100 gals.	February 521,519
Beacon Heights Leachate :	674,147 gals.	March 674,147
Total Phosphorous Discharged :	lbs./day	
Total Nitrogen Discharged :	lbs./day	1st Quarter Leachate 1,669,640 gallons

EMERGENCY CALLS & ALARMS :
None to report.

Repair or Replacement :
3-11 fixed Railroad ave. pump stations backflow preventer on the city water line, it would not seat (stuck opened)
3-30 & 31 put 6X6 on backside of catch basins to keep debris from falling in.

Testing :
4-3 Started a trail run with a new product for phosphorus removal
We started using ACT lab for our BOD testing per State DEEP recommendation

Misc.:
The plant is starting to respond a bit better from the difficult time we had this winter.

Ongoing :
Knapp Engineering still working on installing new SCADA system computers and software

Meetings / Classes :
BOS/BOF Budget meeting for WPCF canceled (COVID-19)

Thank you,
For letting me serve.

Thomas A. Carey
WPCF Superintendent