



TOWN OF

BEACON FALLS

CONNECTICUT

WPCF

Monthly Report

May 2021 Meeting / April 2021 Data

Total Flow (RAW SEWAGE) : 10,731,400 gals.
Total Septage Received : 19,950 gals.
Total Sludge Removed : 146,400 gals.
Beacon Heights Leachate : 610,495 gals.
Total Phosphorous Discharged : 4.17 lbs./day
Total Nitrogen Discharged : 54.75 lbs./day

Beacon Heights Leachate

EMERGENCY CALLS & ALARMS :

4-24 WPCF blower problem / low air.
4-24 WPCF RAS high level alarm

Repair or Replacement :

4-12 Knapp fixed flow signal to PAC shed also got quote programing sampler and blower alarm.
4-27 Bob Parrot calibrated flow meters and O2 sensors at WPCF

Testing :

Quarterly ATMR samples were tested and passed

Misc.:

4-6 Spread woodchips along bank at the treatment plant.
4-15 Tom Pratt on-site W/ Sloss for emergency lighting eval.
WPCA meeting canceled (no quorum)

Ongoing :

Keeping sludge levels down for digester roof job
4-7 Jetted sewer line on Fairfield Pl. W/ McVac.

Meetings / Classes :

4-9 Monthly meeting with Gerard
4-14 Safety meeting canceled

*Thank you,
For letting me serve.*

Thomas A. Carey

WPCF Superintendent