



TOWN OF

# BEACON FALLS

CONNECTICUT

## WPCF

### Monthly Report

August 2020 Meeting /July 2020 Data

Total Flow (RAW SEWAGE) :	8,270,200 gals.	Beacon Heights Leachate
Total Septage Received :	12,050 gals.	
Total Sludge Removed :	158,600 gals.	
Beacon Heights Leachate :	No Data gals.	
Total Phosphorous Discharged :	1.64 lbs./day	
Total Nitrogen Discharged :	53.75 lbs./day	

#### EMERGENCY CALLS & ALARMS :

7-11 power outage at Pines bridge pump station

7-17 called out to White birch , not our problem it was a E-1 pump issue.

#### Repair or Replacement :

repaired a chemical addition line from PAC shed

replaced valve on soda ash tank

#### Testing :

7-20,22,24 Our annual chronic testing was preformed

7-28 Our quarterly ATMR was preformed

#### Misc.:

Received quotes this month for three separate jobs :

WPCF garage door

WPCF building water heaters ( cap. Project )

Hockanum Glen, manhole lid replacement job

Flushed all wet wells to remove grease and debris build up

#### Ongoing :

#### Meetings / Classes :

None to report

*Thank you,  
For letting me serve.*

*Thomas A. Carey  
WPCF Superintendent*

[illegible]