



TOWN OF

# BEACON FALLS

CONNECTICUT

## WPCF Monthly Report

September 2020 Meeting /August 2020 Data

Total Flow (RAW SEWAGE) :	8,294,300 gals.	Beacon Heights Leachate
Total Septage Received :	9,750 gals.	
Total Sludge Removed :	146,400 gals.	
Beacon Heights Leachate :	65,642 gals.	
Total Phosphorous Discharged :	1.79 lbs./day	
Total Nitrogen Discharged :	49 lbs./day	

### EMERGENCY CALLS & ALARMS :

8-4 Tropical storm : Railroad ave. pump station was with out power for 5 days ( 100 hrs. ).  
8-16 Wesr rd. pump station alarm (low flow)

### Repair or Replacement :

8-3 Had three new bolt down and gasketed manhole lids installed at the Hockanum Glen easement to reduce odors.  
8-5 SSI serviced our VFD's at WPCF and RR ave pump station  
8-11 Four new water heaters installed at WPCF and all pump stations.  
Knapp made a few visits to the plant this month to trouble shoot the SCADA installation.  
8-19 Overhead door installed a new garage door at WPCF

### Testing :

8-24 Aquarion water ran tests on all of our back flow preventers

### Misc.:

8-25 working on purchasing more fittings for our 8" Global pump and servicing it.

### Ongoing :

Hockanum Glen odor complaints

### Meetings / Classes :

*Thank you,  
For letting me serve.*

*Thomas A. Carey  
WPCF Superintendent*