



TOWN OF

BEACON FALLS

CONNECTICUT

WPCF Monthly Report

August 2021 Meeting / July 2021 Data

Total Flow (RAW SEWAGE) :	11,812,500 gals.	Beacon Heights Leachate
Total Septage Received :	15,500 gals.	
Total Sludge Removed :	201,300 gals.	
Beacon Heights Leachate :	502,098 gals.	
Total Phosphorous Discharged :	2.15 lbs./day	
Total Nitrogen Discharged :	49.75 lbs./day	

EMERGENCY CALLS & ALARMS :

137 Cedar Ln. Call for sewer back-up. Main line clear, lateral problem.

We had a few Days during July where we had to run the Pine bridge generator do to Eversource line work.

Repair or Replacement :

7-8 Greco & Haines had to work on the well water pump , it kept shutting off.

7-20

Testing :

7-21 Sent Quarterly ATMR samples out. (We passed)

7-25,27 & 29 Sampled the plant effluent and the river water for our annual Chronic test.

Misc.:

7-6 Novus installed VPN for purchase order request.

Ongoing :

7-6 George from SLR engineering was on site to get familiar with the plant.

Meetings / Classes :

7-7 Monthly meeting with Gerard.

7-14 Purchase request training.

7-15 WPCA meeting Canceled (no quorum)

7-20 Quarterly Safety meeting.

*Thank you,
For letting me serve.*

*Thomas A. Carey
WPCF Superintendent*

