



TOWN OF

BEACON FALLS

CONNECTICUT

WPCF Monthly Report

September 2021 Meeting / August 2021 Data

Total Flow (RAW SEWAGE) :	9,544,300 gals.
Total Septage Received :	18,500 gals.
Total Sludge Removed :	244,000 gals.
Beacon Heights Leachate :	582,906 gals.
Total Phosphorous Discharged :	1.98 lbs./day
Total Nitrogen Discharged :	49 lbs./day

EMERGENCY CALLS & ALARMS :

8-6 West Road Pump Station : Pump Failed to Run alarm ; Steve and Ryan dispatched, backflushed both pumps (ok)
8-25 SCADA Problems : Knapp on site, WIN 911 not calling out. Restarted and tested (ok)

Repair or Replacement:

8-31 Forest Construction Co. : Manhole Installation on Fairfield Place
8-26 GMC 2500 work truck to Hillside Auto for Glow Plug Sensor replacement

Testing :

Normal Weekly Testing

Misc.:

8-20 Aquarion Water at Pump Stations to check backflow preventers
8-25 & 8-26 McVac at Cook Lane to camera entire street. Transite Pipe looks in good condition,
Iron Pipe has some tuberculation, Some excess grease throughout

Ongoing :

8-2 Soda Ash Delivery	8-11 Cleaned Pinesbridge P.S. of grease
8-5 Cleaned Contact Tank	8-31 PAC Delivery 1,511 gallons
8-6 Cleaned West Rd. P.S. of grease	

Meetings / Classes:

8-24 WPCA meeting

Thank You,

Steven J. Cherhoniak
WPCF Assistant Superintendent

