



TOWN OF

BEACON FALLS

CONNECTICUT

WPCF Monthly Report

October 2021 Meeting / September 2021 Data

Total Flow (RAW SEWAGE) : 11,320,800 gals.
Total Septage Received: 8,300 gals.
Total Sludge Removed : 237,900 gals.
Beacon Heights Leachate : No Data
Total Phosphorous Discharged : 1.68 lbs./day (Partial Average) waiting on last week of Sept. lab results
Total Nitrogen Discharged : 59 lbs./day (Partial Average) waiting on last week of Sept. lab results

EMERGENCY CALLS & ALARMS :

9-5 Call in for West Rd Pump Station Power Loss
9-6 Call in for Pinesbridge Pump Station Power Loss
9-10 Call in for Pinesbridge Pump Station Power Loss

Repair or Replacement :

9-22 Replaced rusted gate valve with ball valve at ITT Marlow Pump Discharge PSI Gauge

Testing :

Normal Weekly Testing

9-10 Dye test @ 151 Burton Rd.

9-16 State contracted engineering firm (Weston & Sampson) on site. Took Sludge, Influent, Effluent and River samples for PFAS study

Misc.:

9-13 Knapp on site to hook up 4-20mA signal to new sampler for flow based samples

9-13 Ed the Treeman at Pinesbridge, West Road Pump Stations and Treatment Plant for tree work

9-16 Northeast Generator at Pump Stations and Treatment Plant to perform preventative maintenance on generators

9-30 DPW put fresh coat of millings on roadway through solar panels

Ongoing :

9-9 Soda Ash Delivery

9-23 Cleaned Pinesbridge P.S. of grease

9-17 Cleaned Contact Tank

9-24 Cleaned Railroad Ave. P.S. of grease

9-21 Cleaned West Rd. P.S. of grease

Meetings / Classes :

9-1 Monthly Meeting with Gerard

9-16 Met with Forest Construction to look at Hockanum Glen easement manhole and Main Street manhole in front of Bank (awaiting call to schedule work)

9-21 WPCA Meeting Canceled

Thank you,

Steven J. Cherhoniak
WPCF Assistant Superintendent

