

WPCF Monthly Report December 2021 Meeting / November 2021 Data

Total Flow (RAW SEWAGE) :	10,926,900 gals.
Total Septage Received :	6,500 gals.
Total Sludge Removed :	183,000 gals.
Beacon Heights Leachate :	482,209 gals.
Total Phosphorous Discharged :	6.49 lbs./day
Total Nitrogen Discharged :	50.2 lbs./day

EMERGENCY CALLS & ALARMS :

11-18 Call in - Wet Well Level Lo-Lo Float Railroad Ave P.S. ; Cleaned RRA Basket, tail of rags hanging from bottom 11-25 Call in - Wet Well Level Out of Range Railroad Ave P.S.

Repair or Replacement :

11-8 Two Hi-Level floats ordered for RRA pump station and Influent pump station at plant11-22 Snow Blower serviced11-29 Bad Transducer at RRA pump station ; will be ordered and replaced as soon as possible

Testing:

Normal Weekly Testing

Misc.:

11-2 Winterized PAC shed11-24 Pumped out, cleaned and inspected Grit Chamber - OK11-17 Calibrated Confined Space Gas Meter11-29 Added Fuel to WR PS- Full11-18 Fall Cleanup11-15 Added Fuel to Treatment Plant- Full ; 11-19 Added Fuel to RRA & PB Pump station - FullOngoing :11-8 Cleaned WR Pump station of grease11-9 Cleaned PB Pump station of grease11-19 Cleaned Ken Nozzle11-18 Cleaned RRA Pump station of grease ; Cleaned Contact tank

Meetings / Classes : 11-3/11-10/11-12/11-19/11-23 Don Gonyea from SLR on site 11-16 WPCA meeting 11-29 Deputy Fire Marshall Cal Brennan on site for walk through inspection

Thank you,

Steven J. Cherhoniak WPCF Assistant Superintendent