

WPCF Monthly Report

January 2022 Meeting / December 2021 Data

Total Flow (RAW SEWAGE): 9,726,800 gals. Beacon Heights Leachate

Total Septage Received: 11,000 gals. 4th Quarter October 579,817 gallons Total Sludge Removed: 195,200 gals. November 482,209

Beacon Heights Leachate: 489,334 gals. December 489,334

Total Phosphorous Discharged : 8.22 lbs./day

Total Nitrogen Discharged: 47.25 lbs./day Total: 1,551,360 gallons

Emergency calls & alarms:

12-1 Call in - Blower Problem - Low CFM

Repair or Replacement:

12-1 Ober-Read service to Blowers

12-2 Knapp replaced Hi Level floats at Railroad Ave. P.S. and Treatment Plant P.S.

12-3 Forest Construction removed and replaced manhole at Hockanum Glen/Skokorat easement repaired invert in manhole on Main St.

12-14 Knapp replaced transducer at Railroad Ave. P.S.

12-29 LeClaire HVAC replaced primary control on boiler

Testing:

Normal Weekly Testing

Misc.:

12-2 Permit renewal application sent to DEEP via SLR 12-27 LeClaire HVAC cleaned boiler

12-15 Pumped out, cleaned and inspected Thickener 12-28 Removed U.V. for winter storage and maintenance

12-23 Hach on site for preventative maintenance to Lab equipment/DO probes/Composite samplers

We were short handed 21 days this month

Ongoing:

12-14 Cleaned Railroad Ave. P.S. of Grease12-20 Cleaned Ken Nozzle12-15 Cleaned West Rd. P.S. of Grease12-30 Cleaned Contact Tank

12-16 Cleaned Pinesbridge Rd. P.S. of Grease

Meetings / Classes:

12-7 Ryan completed Bypass Reporter Training 12-13 George(SLR) & John(EESC) power to roof for mixer (Upgrade)

12-8 Steve completed Bypass Reporter Training 12-20 George/Glen(SLR) Influent P.S. roof repair

12-13 CIRMA risk management meeting 12-3/12-9/12-16/12-21/12-28 Don Gonyea from SLR on site

12-21 WPCA Meeting Canceled

Thank you,

Steven J. Cherhoniak WPCF Assistant Superintendent