



TOWN OF

BEACON FALLS

CONNECTICUT

WPCF Monthly Report

October 2020 Meeting / September 2020 Data

Total Flow (RAW SEWAGE) : 7,956,200 gals.
Total Septage Received : 12,250 gals.
Total Sludge Removed : 115,900 gals.
Beacon Heights Leachate : No Data gals.
Total Phosphorous Discharged : No Data lbs./day
Total Nitrogen Discharged : No Data lbs./day

Beacon Heights Leachate
Have not received report yet I will
send Kerri the info when it arrives

EMERGENCY CALLS & ALARMS :

None to report

Repair or Replacement :

9-25 Repaired backflow preventer at RR ave pump station
9-17,18,21 Kovacs installed new digester pipping
9-25 Aquarion water installed new meter at Pines bridge

Testing :

9-30 Northeast generator minor PM

Misc.:

9-1 Global pump rep. looked over 8" pump and recommended servicing it
9-10 American rooter preformed smoke test at Hockanum Glen easement
9-11 Northeast generator / trouble shoot treatment plant generator
9-17,18,21 Mcvac / digester cleaning

Ongoing :

Meetings / Classes :

9-22 After Action Debriefing & Future Planning meeting
9-22 NVCOG Natural Hazard Mitigation Plan Update meeting

*Thank you,
For letting me serve.*

*Thomas A. Carey
WPCF Superintendent*