



TOWN OF

BEACON FALLS

CONNECTICUT

WPCF Monthly Report

November 2020 Meeting / October 2020 Data

Total Flow (RAW SEWAGE) :	9,845,900 gals.	Beacon Heights Leachate
Total Septage Received :	22,500 gals.	
Total Sludge Removed :	140,300 gals.	
Beacon Heights Leachate :	No Data gals.	
Total Phosphorous Discharged :	.73 lbs./day	
Total Nitrogen Discharged :	60 lbs./day	

EMERGENCY CALLS & ALARMS :

10-3 Railroad ave pump station high level alarm
10-6 Railroad ave pump station high level alarm
10-30 West Rd pump station power loss alarm

Repair or Replacement :

10-16 WJ electric was here to disconnect some obsolete pieces of machinery

Testing :

10-20 sent out samples for our ATMR test, the results came back everything passed.

Misc.:

10-16 American rooter preformed jet work on Feldspar and at the Naugatuck river siphon.
10-22 McVac was scheduled for video inspection of Feldspar line. House # 160 had a sewer back-up. The inspection showed the main line was clear, the home owner had a problem with their lateral

Ongoing :

10-16 Knapp was here working out a few kinks in the SCADA system

Meetings / Classes :

10-15 NVCOG zoom meeting (regionalization study). Gerard.S, Jeff.S and myself were in attendance

*Thank you,
For letting me serve.*

*Thomas A. Carey
WPCF Superintendent*

