



TOWN OF

BEACON FALLS

CONNECTICUT

WPCF Monthly Report

December 2020 Meeting / November 2020 Data

Total Flow (RAW SEWAGE) :	11,094,700 gals.	Beacon Heights Leachate
Total Septage Received :	7,750 gals.	
Total Sludge Removed :	140,300 gals.	
Beacon Heights Leachate :	No Data gals.	
Total Phosphorous Discharged :	7.79 lbs./day	
Total Nitrogen Discharged	81.5 lbs./day	

EMERGENCY CALLS & ALARMS :

11-20 West rd. pump alarm / pump # 2 plugged with rags
11-21 Pulled West rd. #2 pump / cleaned and back in service

Repair or Replacement :

11-5 Ober-Read serviced WPCF blowers

Testing :

Misc.:

11-12 Sonicwall / firewall was set up at the WPCF
Winterized critical areas at WPCF and Pump stations

Ongoing :

11-2 Novus was on site working on computer issues
Leave cleaning at WPCF and pump stations

Meetings / Classes :

11-4 Alge wheel webinar
11-18 NVCOG Regional wastewater workshop (zoom meeting)
11-18 NVCOG Regional hazard mitigation workshop (zoom meeting)

*Thank you,
For letting me serve.*

*Thomas A. Carey
WPCF Superintendent*

