



TOWN OF

BEACON FALLS

CONNECTICUT

WPCF Monthly Report

January 2020 Meeting / December 2020 Data

Total Flow (RAW SEWAGE) : 16,335,500 gals.
Total Septage Received : 9,750 gals.
Total Sludge Removed : 73,200 gals.
Beacon Heights Leachate : No Data gals.
Total Phosphorous Discharged : 10.75 lbs./day
Total Nitrogen Discharged : 96 lbs./day

Beacon Heights Leachate

I will send Kerry the 4th quarter leachate totals when I
Receive Decembers flow.

EMERGENCY CALLS & ALARMS :

12-2 Pines Bridge / High water alarm
12-16 Power loss at Pines Bridge pump station
12-17 & 18 Snow event
12-27 Heavy rain / Plant overload

Repair or Replacement :

12-18 Northeast Generator installed a new timer on the electrical transfer switch at the plant

Testing :

No extra testing , just the normal weekly test

Misc.:

12-30 McVac preformed video inspection of the main line and lateral at 63 Highland ave. (repair work is needed) and scheduled for after the Holiday.

Ongoing :

Dealing with the cold weather and trying to keep the bugs happy.

Meetings / Classes :

No meetings this month

*Thank you,
For letting me serve.*

*Thomas A. Carey
WPCF Superintendent*

