

WPCF Monthly Report

February 2021 Meeting / January 2021 Data

Total Flow (RAW SEWAGE) : Total Septage Received : Total Sludge Removed : Beacon Heights Leachate : Total Phosphorous Discharged : Total Nitrogen Discharged : 13,819,400 gals. 5,300 gals. 73,200 gals. NO Data gals. 11.43 lbs./day 83 lbs./day **Beacon Heights Leachate**

EMERGENCY CALLS & ALARMS :

Snow detail 2-4,2-27

1-11 Conn - Professional Water Service fixed pipping issue at 63 Highland ave (sewer repair in street)

1-13 Had to shut off low pressure force main at 15 Hockanum for interior plumbing repair

1-14 Main line sewer blockage on Noe Place. American rooter cleared the line

1-24 sewer back up at 4 Bronson Dr. (lateral problem)

Repair or Replacement : 1-6 Knapp was working on our SCADA system

Testing :

We ran our quarterly ATMR (toxicity) this month and we past. 1-28 Greco & Haines annual service to our well pump system.

Misc.:

2-6 Arcadis/Beacon Heights stopped in to discuss their new permitKinsley and Northeast generator looked at R.R ave generator for possible radiator installation.1-27 SSI preformed semi annual preventative maintenance to our VFD's

Ongoing : Digester roof and electrical upgrade projects Snow removal

Meetings / Classes : 1-6 Monthly in house meeting with Gerard 1-13 Zoom safety meeting

Thank you, For letting me serve.

'Thomas A. Carey WPC'F Superintendent