



TOWN OF

BEACON FALLS

CONNECTICUT

WPCF Monthly Report

March 2021 Meeting / February 2021 Data

Total Flow (RAW SEWAGE) : 11,459,900 gals.
Total Septage Received : 1,000 gals.
Total Sludge Removed : 73,200 gals.
Beacon Heights Leachate : No Data gals.
Total Phosphorous Discharged : 12.80 lbs./day
Total Nitrogen Discharged : 73.75 lbs./day

Beacon Heights Leachate

EMERGENCY CALLS & ALARMS :

2-1 Pines bridge power loss
2-3 WPCF Generator lost prime
2-10 communication loss on SCADA

Repair or Replacement :

oil change and front brake pads done on utility truck

Testing :

Normal weekly testing preformed

Misc.:

Snow detail 2-1, 2,7,9,11,18,
2-17 Confined space awareness training (I think we all still need to be certified)
2-25 Synagro on site visit for possible storage tank cleaning

Ongoing :

Digester roof and electrical upgrade projects

Zoom Meetings

2-3 NVCOG meeting
2-3 Kovacs and DPC / Digester project
2-5 Regional wastewater study / workshop
2-11 Meeting with Synagro on possible storage tank cleaning

*Thank you,
For letting me serve.*

*Thomas A. Carey
WPCF Superintendent*

