



TOWN OF

# BEACON FALLS

CONNECTICUT

## WPCF Monthly Report

April 2021 Meeting / March 2021 Data

Total Flow (RAW SEWAGE) :	11,754,900 gals.	Beacon Heights Leachate
Total Septage Received :	6,750 gals.	I will send Kerry the quarterly numbers when I receive them.
Total Sludge Removed :	114,600 gals.	
Beacon Heights Leachate :	No Data gals.	
Total Phosphorous Discharged :	9.59 lbs./day	
Total Nitrogen Discharged :	61 lbs./day	

### EMERGENCY CALLS & ALARMS :

3-2 West rd. pump station power loss  
3-14 West rd. pump station power loss  
3-23 took #3 aeration tank off line and balanced other tanks  
3-27 Solids leaving plant had waste and remove extra mixed liquor from the system

### Repair or Replacement :

3-8 Northeast generator: Major PM on all our generators  
3-24 Brought escape to Shakers / front brakes and tune-up

### Testing :

none to report

### Misc.:

3-11 Knapp was on site to trouble SCADA issues

### Ongoing :

Digester roof job

### Meetings / Classes :

3-3 Gerard monthly meeting at WPCF  
3-22 Zoom meeting with DPC and Kovacs on moving forward on digester roof job  
3-23 Budget workshop

*Thank you,  
For letting me serve.*

*Thomas A. Carey  
WPCF Superintendent*

