



TOWN OF

# BEACON FALLS

CONNECTICUT

## WPCF Monthly Report

June 2021 Meeting / May 2021 Data

Total Flow (RAW SEWAGE) : 10,333,000 gals.  
Total Septage Received : 5,500 gals.  
Total Sludge Removed : 176,900 gals.  
Beacon Heights Leachate : 505,609 gals.  
Total Phosphorous Discharged : 2.63 lbs./day

Beacon Heights Leachate

Total Nitrogen Discharged : 54 lbs./day  
EMERGENCY CALLS & ALARMS :  
5-7 pump back-up at 30 Hockanum Glenn, Home owner issue.  
5-15 West Rd. pump station alarm  
5-29 SCADA alarm repeater communications loss  
5-30 SCADA alarm Polling master power loss

Repair or Replacement :  
5-25 Steve and I had new computers installed in our office by Novus.  
5-26 Knapp engineering worked on Scada/TeamViewer problems.

Testing :  
nothing out of the ordinary just the normal weekly testing.

Misc.:  
We no longer have a foam blanket on the aeration tanks , we are through our seasonal transition. The plant looks good.  
Aeration tank #3 is being drained and cleaned so we can install new diffusers

Ongoing :  
Decanting the clear water from our storage tanks and keeping as little as possible in them to be ready for digester cover.

Meetings / Classes :  
5-5 monthly morning with Gerard

*Thank you,  
For letting me serve.*

*Thomas A. Carey  
WPCF Superintendent*