

## **WPCF Monthly Report** June 2022 Meeting / May 2022 Data

Total Flow (RAW SEWAGE): **Total Septage Received : Total Sludge Removed :** Beacon Heights Leachate : **Total Phosphorous Discharged : Total Nitrogen Discharged :** 

11,224,700 gals. 11,000 gals. 164,700 gals. 446,400 gals. 2.27 lbs./day 30 lbs./day

**Beacon Heights Leachate** April: 441,957

**EMERGENCY CALLS & ALARMS :** 5-10 Pines Bridge P.S alarm

**Repair or Replacement :** 5-20 Deragged both sludge loading pumps New motor for RAS pump is on-site and being scheduled for install ordered two new block heaters for P.S generators.

Testing :

Misc.: 5-10 Pines Bridge P.S alarm 5-16 Cleared one of the three sewer lines that go under the river ( clump of rags ). 5-26 Camera work preformed at 42 Rice lane to locate lateral connection.

Ongoing : inside and outside House keeping, plus lawn maintenance Still waiting on price break down for the electrical upgrade.

Meetings / Classes : Steve had class every Thursday in May, prep class for the class III exam 5-4 Monthly meeting with Gerard

Thank you, For letting me serve.

'Thomas A. Carey WPC'F Superintendent