



TOWN OF

BEACON FALLS

CONNECTICUT

WPCF Monthly Report

November 2022 Meeting / October 2022 Data

Total Flow (RAW SEWAGE)	9,566,900 gals.	Beacon Heights Leachate	
Total Septage Received :	10,450 gal.	July	449,286 Gall
Total Sludge Removed :	115,900 gals.	August	432,000 Gall
Beacon Heights Leachate :	No Data gals.	September	562,736 Gallon
Total Phosphorous Discharged :	1.65 lbs./day	3rd QT Total	1,443,736 Gallon
Total Nitrogen Discharged :	27 lbs./day		

EMERGENCY CALLS & ALARMS :
None to report

Repair or Replacement :
Changed oil in all drives on the Thickener, Primary and Secondary tanks.

Testing :
10-18 Quarterly ATMR sampling

Misc.:
Getting WPCF ready for winter
Winterized PAC shed Pipping and insulated soda ash line to our wet well.

Ongoing :
Dealing with a little foam at the plant , typical with the change in seasons. Not to bad
Continuing to work on OSHA citations.

Meetings / Classes :
10-12 Met with Conn-OSHA to go over lock-out and confined space citations
10-17 Met with Natasha to discuss any changes needed in the Sludge RFP prior to putting it out for bid.
10-20 Teams meeting with Kovacs,SLR,Natasha and myself. (Digester change order)

*Thank you,
For letting me serve.*

*Thomas A. Carey
WPCF Superintendent*

