



WPCF Monthly Report

July 2020 Meeting / June 2020 Data

Total Flow (RAW SEWAGE) :	9,979,500 gals.	Beacon Heights Leachate
Total Septage Received :	14,950 gals.	April 698,718 gal
Total Sludge Removed :	219,600 gals.	May 491,535 " "
Beacon Heights Leachate :	253,637 gals.	June 253,637 " "
Total Phosphorous Discharged :	2.97 lbs./day	Total 1,443,890
Total Nitrogen Discharged :	75 lbs./day	

EMERGENCY CALLS & ALARMS :

6-24,26,29 12 Hockanum Glen Rd. odor complaint. We are working on having new sealing lids installed and having the manhole interior coated

Repair or Replacement :

6-15 Rebuilt and installed #2 RAS pump

6-16 Knapp engineering worked on getting some of the kinks out of our SCADA system

Testing :

None to report

Misc.:

I am getting estimates for a new garage door at the WPCF

6-17 Mcvac was at the WPCF to clean out our grit pit

drained and hosed down walls of #3 aeration tank. Will change diffusers early fall

Ongoing :

Landscaping at WPCF and pump stations

Meetings / Classes :

6-25 NVCOG virtual workshop

*Thank you,
For letting me serve.*

*Thomas A. Carey
WPCF Superintendent*

